



SUBJECT: Amendment No. 1 to Request for Proposal No. 2013-01-DETR

DATE OF AMENDMENT: April 5, 2013

DATE OF RFP RELEASE: March 13, 2013

DATE AND TIME OF OPENING: April 19, 2013 @10:00 AM

AGENCY CONTACT: James Lewandowski, Program Officer I

---

The following shall be a part of RFP No. **2013-01-DETR** for *HVAC Service Maintenance Contract*. If a vendor has already returned a proposal and any of the information provided below changes that proposal, please submit the changes along with this amendment. You need not re-submit an entire proposal prior to the opening date and time.

---

**Questions and Responses to RFP:**

Question No. 1: Will State of Nevada staff be responsible or assist with removing and installing the floor panels to gain access to the under floor units? **Yes.**

Question No. 2: Can work on the under floor units be performed on Saturdays? **Yes.**

Question No. 3: Can sub contractor references be provided after award of job? Primary contractor references will be provided as part of the response to the RFP. **No, three references for each subcontractor must also be submitted, per the RFP instructions, by 10:00 a.m. on April 19, 2013.**

Question No. 4: Does the Bell & Gossett plate and frame heat exchanger get opened and cleaned one time per year? **No.** Is the contractor responsible to provide and install any replacement parts that may be required? **Yes.**

**ALL ELSE REMAINS THE SAME FOR RFP 2013-01-DETR.**

Vendor shall sign and return this amendment with proposal submitted.

NAME OF VENDOR \_\_\_\_\_

AUTHORIZED SIGNATURE \_\_\_\_\_

TITLE \_\_\_\_\_ DATE \_\_\_\_\_

***RFP 1870 Amendment 1***

This document must be submitted in the "State Documents" section/tab of vendors' technical proposal